



1 ROOF PLAN - MECHANICAL  
1/4" = 1'-0"

- GENERAL NOTES:
- A. MOUNT ALL HVAC EQUIPMENT ON ROOF PER DETAILS ON SHEET M5.1.
  - B. CONTRACTOR TO MAINTAIN MINIMUM MANUFACTURER RECOMMENDED SERVICE CLEARANCE AROUND EACH PIECE OF EQUIPMENT.
  - C. CONTRACTOR TO ENSURE A MINIMUM OF 10' CLEARANCE BETWEEN ALL OA INTAKES AND ANY EXHAUST FANS, VENTS, FLUES, ETC.
  - D. CONTRACTOR TO ENSURE ALL MECHANICAL EQUIPMENT IS INSTALLED A MINIMUM OF 10' FROM THE ROOF EDGE WHERE PARAPET IS 36" HIGH OR LESS.
  - E. COORDINATE EXHAUST LOCATION OF RTUS WITH STRUCTURE TO ENSURE DUCT DROPS ARE LOCATED WITHIN TRUSS.

- CODED NOTES: (#)
- 1. CONDENSING UNIT SHOWN FOR REFERENCE ONLY. EQUIPMENT AND ASSOCIATED REFRIGERANT PIPING TO BE INSTALLED BY KITCHEN EQUIPMENT SUPPLIER.
  - 2. PLUMBING VENT/ FLUE PIPING SHOWN FOR REFERENCE. MAINTAIN A MINIMUM OF 10'-0" CLEARANCE TO ANY OA INTAKE.
  - 3. RTU'S MOUNTED ON CURB ON ROOF. REFER TO DETAIL ON SHEET M5.1 FOR FURTHER INFORMATION.
  - 4. ZONE LOCATED 10' FROM EDGES OF BUILDING SHOWN FOR REFERENCE ONLY.
  - 5. WATER HEATER FLUE PENETRATIONS SHOWN FOR REFERENCE.
  - 6. WALK-IN COOLER VENDOR TO PROVIDE REFRIGERANT LINES FROM ROOF MOUNTED CONDENSING UNITS TO EVAPORATORS IN WALK-IN COOLERS. WALK-IN COOLER VENDOR TO ROUTE THRU PREFABRICATED ROOF CURB TO ABOVE THE CEILING AND DOWN THRU FURRED OUT WALL INTO THE WIC BOX. COORDINATE EXACT LOCATIONS WITH G.C. PRIOR TO INSTALLATION. G.C. TO PROVIDE SLEEVE IN WALL FROM WALK-IN COOLER ROOF UP TO CEILING SPACE ABOVE KITCHEN. REFER TO ARCHITECTURAL WALL SECTIONS.



PROPRIETARY INFORMATION NOTICE:  
THESE PROTOTYPICAL DOCUMENTS MAY REQUIRE REVISIONS TO CONFORM TO LOCAL, STATE, AND FEDERAL CODES, ORDINANCES OR OTHER CONDITIONS. THE DESIGN CONCEPTS EMBODIED IN THESE DOCUMENTS ARE SPECIFICALLY FOR THIS PROJECT. INFORMATION CONTAINED HEREIN REMAINS THE SOLE PROPERTY OF ARBY'S RESTAURANT GROUP. IS CONFIDENTIAL AND PROPRIETARY AND IS NOT TO BE COPIED, REPRODUCED, DISCLOSED OR OTHERWISE TRANSFERRED TO OTHER PARTIES IN ANY FORM WHATSOEVER WITHOUT THE EXPRESS WRITTEN CONSENT OF ARBY'S RESTAURANT GROUP.



ARBY'S RESTAURANT GROUP  
INSPIRE DUAL REGULAR 40 - STANDARD  
1632 AR-25 BYPASS  
HEBER SPRINGS, AR 72543  
FOR  
RB AMERICAN GROUP, LLC  
6200 OAK TREE BLVD., SUITE 250, INDEPENDENCE, OHIO 44131

PROJECT NUMBER:	
ISSUE	DATE
PRELIMINARY	
PERMIT	
BID	
REVISION	

ROOF PLAN  
MECHANICAL

SHEET:

M3.1